

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0495:110 Page 1 of 1

CATEGORY: Control Units (Household)

LISTEE: Fire Burglary Instruments, *165 Eileen Way, Syosset NY 11791
Contact: Harold Wagner (516) 921-8666

DESIGN: Models XL2, XL4605DL, 6701, 6801, XL4600DL, LEGEND 70 Model 6700, and LEGEND 80 Model 6800. Refer to listee's data sheet for detailed product description and operational considerations. System components:

XL4600RM/XL4600RP/XL4600LCDP	Keypads
6615/6805	Keypads
EOL2.2K	EOL Resistor
BE114520CAA	Transformer
VS-279/VS-679	Siren Driver

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as household control units for use with the following devices: ESL/Sentrol Model 204A EOL Relay Module (CSFM Listing No. 7300-0447:018); and, ESL/Sentrol Model 445AT Smoke Detector (CSFM Listing No. 7272-0447:104), ADEMCO Models AD10-12 or MBL-8 Bell (CSFM No. 7135-0078:107).

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE:

1. Burglary and other non-fire functions were not examined. Refer to listee's data sheet or installation instructions for compatible non-fire devices.
2. Formerly 7165-0495:110

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 10, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager